



# Town of South Kingstown, RI

Department of Public Services

509 Commodore Perry Highway

Wakefield, RI 02879

Tel: (401) 789-9331

Fax: (401) 782-8068


## SEWER SERVICE ENGINEERING REVIEW REQUEST

Review Requested By: Nick Hayes

Property Address: Oak Street (A is connected to sewer – B (two units are not connected))

Plat: 57-1 226 Road Status:  Town  Private  State

- SEWER SERVICE IS AVAILABLE AT THIS TIME\* (See Note)
- SEWER SERVICE IS AVAILABLE AT THIS TIME, BUT REQUIRES LATERAL INSTALLATION AT PROPERTY OWNER'S EXPENSE
- SEWER SERVICE IS NOT AVAILABLE AT THIS TIME
- SEWER MAIN EXTENSION REQUIRED
- GREASE TRAP REQUIRED; CONTACT KRYSTAL FURLONG, PRETREATMENT COORDINATOR, AT 788-9771 FOR MORE INFORMATION.
- UTILITIES IN A STATE RIGHT-OF-WAY WILL REQUIRE A RIDOT INSPECTION. APPLICANT SUBJECT TO PAY ALL RIDOT INSPECTION FEES.
- OTHER: Sewer work to be performed by a RI Licensed Undergroud Utility Contractor.  
Sewer cleanout at property line for both properties. Sewer clean check valve within 5 feet of face  
of foundation.10' minimum separation between sewer and water service. Contact Sewer  
Department for associated fees. Confirm the existing location of sewer service with a test hole  
prior to recording.

  
RICHARD J. BOURBONNAIS, PE, Public Services Director  
KATHY PEREZ, Wastewater Superintendent

10-9-2024  
DATE

**\*NOTE:** The Town makes no warranty either written or implied as to the accuracy of lateral installation. Confirmation of lateral is only warranted upon test-pit verification at property owner's expense.